

Este informe contiene informacion muy importante sobre su agua potable.

Tradí.1zcalo o hable con alguien que lo entienda bien.

CANCELLATION OF BOIL WATER NOTICE

Tehachapi Cummings County Water District (TCCWD) Water System (System No. 1502277)

On July 14, 2018 you were notified of the need to boil all tap water used for drinking and cooking purposes. The boil water notice was issued due to a positive *E. coli* sample result from Well 02 (one of the sources of water for the TCCWD Water System).

To resolve the issue, TCCWD disinfected and flushed its wells, its storage tanks, and the distribution system. Multiple water samples were collected from the wells, Tank #1, and the distribution system for bacteriological analysis (Tank #2 remains out of service for further cleanup). This process was repeated until two consecutive rounds of samples were negative for total coliform bacteria.

On July 17, 2018, Wells 01 and 02 were tested for bacteria. Both wells tested negative for total coliform bacteria. On July 26, 2018, one sample from Tank #1 and five samples were collected from the distribution system. On July 27, 2018, another round of one sample from Tank #1 and five samples from the distribution system were collected. All twelve samples were negative for total coliform bacteria. In addition to the total coliform negative samples, TCCWD also took corrective actions to eliminate sanitary hazards, identified by the State Water Resources Control Board, Division of Drinking Water.

TCCWD in conjunction with the State Water Resources Control Board, has determined that, through abatement of the health hazard and comprehensive testing of the water, your water is safe to drink. **It is no longer necessary to boil your tap water or for you to consume bottled water.**


For more information call:

Water Utility contact: Troy DePriest, Operations Manager, TCCWD (760) 315-3349, Alex Steele, Pipeline Superintendent, TCCWD (661) 301-4996, Tom Neisler, General Manager, TCCWD (661) 331-2308

State Water Resources Control Board: Drinking Water Field Operations Branch- District Office at (661) 335-7315.

07/31/18

Date Issued



Tom Neisler, General Manager
Tehachapi Cummings County Water District